





Product Certificate Number	21615-1-CER		
Applicant	Hitachi Energy Ltd. Allée Centrale 10. Z.I. Jumet B-6040, Charleroi, Jumet.		
Series	PQstorl Series		
Models	PQstorl-M PQstorl-WM PQStorl-C		
Type of generating unit	Energy storage Inverter		
Technical Data	See page 2		
Software version	SW: uC 1.0 Rev20/DSP V56.2 rev77		
Model name	PQstorl_RMS_PWFv672_Template_fix.pfd aip_win64.dll digexfun_aip_v670_64bit.dll		
Checksum	7853706CC9B0E1363EEF7D269CDB5D75 0C1551C925F08AE74299BC209BB62CDE D779EE5996EA6FA2D8F05A9E891AAF2A		
Software environment	DigSilent Powerfactory 2022		
Grid connection code	Engineering Recommendation G99 Issue 1 – Amendment 9- 3 October 2022: Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019. Type A & B		

Having assessed the report number: 21614-3-TR and the report number: 21615-S, both performed by CERE (Accredited Laboratory № 5314.01) based on the requirements of the EN ISO/IEC 17025: 2017.

The above-mentioned generating unit complies with the requirements of the:

Engineering Recommendation G99 Issue 1 – Amendment 9- 3 October 2022: Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019. Type A & B

This certification is according to the CERE internal process PET-CERE-09 Rev 35, that defines the certification scheme, based on the requirements of the EN ISO/IEC 17065:2012. For this certification process the conformity assessment activities were based on:

- Testing of production samples selected by CERE.
- Audit of quality system according to ISO 9001 with certificate number: BE05/051523 issued by a certification body accredited according to EN ISO/IEC 17021.
- Inspection of the manufacturing process.

Madrid, February 10, 2023. This certificate is valid until February 10, 2028

Miguel Martínez Lavin, Certification Director






Technical data

Specifications	PQstorl – M (module)	PQstorl – WM	PQstorl - C			
		(Wall mounted)	(Standalone cabinet)			
Electrical characteristics						
AC grid tied connection side						
Connection method	3P3W+PE					
Network voltage (+/ - 10%)	208 - 415 V					
Network frequency (+/ - 5%)	50/60Hz					
Rated power (at 400 V)	30 kW					
Line current rating per	43 A Full cubicle: 43 A 688 A		5 11 11 12 13 2 2 2 2 2 2 2 2 2 2			
base unit (A)			Full cubicle: 43 A 688 A			
DC Energy souce connection side						
DC voltage (min)	620 V for 3 W application (note 1) Note 1: Limited High voltage ride through support at lower DC voltages					
DC voltage (max)	830 V (890 V with reduced power)					
DC current	52A					
Interface / communication						
Wi-Fi communication	Webserver on smartphone or computer for simple diagnostics and parameters setup					
USB	With dedicated optional software (servicing/ programming)					
RJ12	For CAN bus communication between HMI and other modules					
CT inputs	3 ph CT measurements (class 1.0 or better, 15 VA)					
2x 24Vdc inp <mark>ut</mark> s	1 for Emergency stop 1 for external supply					
230V <mark>ac R</mark> elay o <mark>u</mark> tput	For control of external grid contactor/breaker					
Wi-Fi c <mark>om</mark> munication	Webserver on smartphone or computer for simple diagnostics and parameters setup					
,	Dimensions (W x D x H)	78 x 25 x				
PQconnecT	IP protection Communications	IP 20 CAN: RJ12 - 500 kbit/s or 1 Mbit/s Ethernet: 10/100 Mbit, full or half-duplex, HP Auto-MDIX support				
	I/O	1 relay output, normally open, 5 A / 30 VDC				
	7-inch color TFT screen (800 x 480 pixels)					
HMI (optional)	Dimensions (W x D x H)	198 x 141 x 40 mm				
	IP protection	IP65 front side / IP 20 backside				
	Communications	CAN 2B (internal) – RJ12 Ethernet (Modbus TCP) – RJ45 USB 2.0				
	Digital I/O on HMI	2 insulated digital inputs - +24 V (AC or DC) 6 digital NO outputs – 250 Vac/ 5 A (one common polarity), dry contacts				





Electrical Diagram of PQstorl:



The sample selected to test was representative of the

production. The sample was selected in:

Hitachi Energy Belgium N.V.

Allée Centrale, 10 – Z.I. Jumet B-6040 Charleroi,

Belgium

Sample Report Number:

21614<mark>-TM</mark>

The inspection of manufacturing process was performed in:

On November 30, 2022

Hitachi Energy Belgium N.V.

Allée Centrale, 10 – Z.I. Jumet B-6040 Charleroi,

Belgium

Inspection Report Number:

60028-22-1-IF

RECORD OF CHANGES

Revision	Reason of the modification	Modification	Date
0		Initial version	10/02/2023